



50AMP C1A C1B
 SEE BUSSING DIAGRAM
 30kW HTR
 50AMP C2A C2B
 SEE BUSSING DIAGRAM
 30kW HTR

100KVA XFMR

POWER ON

TEMP CONTROLLER #1
 CONTACTOR #1

TEMP CONTROLLER #2
 CONTACTOR #2

TEMP CONTROLLER #3
 LOW TEMP CUT-OFF
 SOLENOID VALVE

HIGH TEMP CUT OFF
 CONTACTOR #1

HIGH TEMP CUT OFF
 CONTACTOR #2

CRYOGENIC EXPERTS INC. CANOGA PARK, CALIFORNIA 91303		
TITLE 60 KW DTP ELECTRIC VAPORIZER ELECTRICAL SCHEMATIC		
CONTRACT NO C-921008-7	DWG NO C-921008-7	REV -
SCALE JOB	DATE 05-07-02	C921008